



1855 Data Drive, Suite 150
Hoover, Alabama 35244
T: 205-983-6000 F: 205-983-6001
www.ahoarch.com

AHO ARCHITECTS, LLC

A R C H I T E C T ' S S U P P L E M E N T A L I N S T R U C T I O N S

ASI NUMBER: **Varies based on Project.**

PROJECT NUMBER: N/A

PROJECT: Express Oil Change & Tire Engineers


DATE OF ISSUANCE: 6/10/2026

DESCRIPTION: Revisions to Construction Documents

1. Amerex Model #760 High Flow is to be used in lieu of Amerex Model #B456 throughout the building except for the office portion of the building which shall remain as Amerex Model #B456. In addition to the model number of the new High Flow extinguisher, it is to be an ABC Dry Chemical Type. Wall bracket to be used shall be (Amerex Model 00577-P) and the UL Rating in 4A:60B:C).

COPIES TO: Express Oil Change & Tire Engineers

SIGNED: _____


Jennifer Hughes